



***Business Operations Division***

BUS-5-5, Construction and Architect-Engineering Contracts Team

P.O. Box 1663, M/S M986

Los Alamos, NM 87545

(505) 66-; FAX (505) 665-3300, dalekemp@lanl.gov

<b>Solicitation No. 73839-001-03-CK</b>	<b>Amendment No. 1</b>	<b>Date: June 9, 2003</b>
<b>ISSUED BY:</b> Dale V. Kemp, Sr. Contract Administrator University of California Los Alamos National Laboratory Los Alamos, NM 87545		<b>PROJECT NAME &amp; LOCATION</b> <b>CCF/LDCC Cooling Plant Modifications</b> <b>TA-03, Los Alamos, New Mexico</b>
<p>The above numbered solicitation is amended as set forth below. <b>The hour and date specified for receipt of offers [ X ] remains unchanged as 2:00 p.m., local prevailing time, June 19, 2003.</b></p>		
<p>FAILURE TO ACKNOWLEDGE THIS ADDENDUM IN ACCORDANCE WITH THE INSTRUCTIONS TO BIDDERS MAY RESULT IN REJECTION OF YOUR BID. EXCEPT AS PROVIDED HEREIN, ALL TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENT REMAIN UNCHANGED AND IN FULL FORCE AND EFFECT.</p>		
<p>Signature of the issuing Contract Administrator</p>		
<p><b>DESCRIPTION OF MODIFICATION</b></p> <p><b>I. SOLICITATION, OFFER AND AWARD DOCUMENTS</b></p> <p>A. Access to the work site, each time an individual enters, will involve the following:</p> <ol style="list-style-type: none"> <li>1. Identification of each individual at one of the guard houses outside the buildings. This will take only a few minutes. Escorts must accompany individuals from this point until they exit again.</li> <li>2. Each individual will then report to the inside security window, on the first floor within the CCF Building, and they will have to identify where they will be working. Changing work locations will require again reporting to the internal security window.</li> <li>3. To exit the CCF/LDCC compound, each individual will have to sign back out at both of these two locations again, even if just for lunch.</li> </ol>		

- B. Minutes from the pre-bid/site visit meeting held June 4, 2003 are attached for information.
- C. The following questions, submitted by interested parties, are provided answers below:
  - 1. Drawing E 1002, Note 4: Where is power source located? ( for both Chiller Purge Condensing Units)
    - A. **Purge condensing units are feed from the chiller control panels. The control panels are feed from the same source as the chillers, SUS-H.**
  - 2. Drawing E1003, Note 2: where is power source located?
    - A. **Purge condensing unit is feed from the CWR-161 control panel. The control panel is feed from SUS-C, same source as the chillers.**
  - 3. Drawing E1003: Need Location for SUS-C-B2 not shown?
    - A. **Room 160R, same room as chiller CWR-161.**
  - 4. Drawing E 1003, Note 6, room 100R, lower left shows removal of disconnect: Is there power at this location (**A. Yes**) and if so where is power source located?
    - A. **Room 100R, same room as chiller CWR-101.**
  - 5. Can the sign-in process be modified?
    - A. **The Facility Security Manager will work with the Contractor daily to minimize the impacts of security requirements, and some of the sign-in and out procedures of the site inspection may be eased after start-up.**
- D. The U. S. Department of Labor, General Wage Decision listed in the Draft Contract Article No. 5, B, 3 is replaced with: "U. S. Department of Labor, General Wage Decision No. NM030001, Modification No. 0, Publication Date: 06/13/2003." This wage decision may be viewed at the Department of Labor's web site: <http://www.gpo.gov/davisbacon/nm.html>. If you cannot access this through the web page, please contact the University to obtain a copy sent another way.

E. The Cover letter for the Solicitation is replaced with the attached, and the following times that are set forth in the superceded letter and the Instructions, Conditions, and Notices to Offerors are revised:

1. The time for the pre-bid conference and site inspection tour is changed to 9:00 a.m., local prevailing time, Wednesday, June 4, 2003.
2. To attend the pre-proposal conference, you must indicate your intention to attend and provide your name, social security number, citizenship, firm name, and how to contact you by not later than noon, Monday, June 2, 2003. Send this information to Carol McNeil, phone 505-667-5866, or e-mail to [cmcneil@lanl.gov](mailto:cmcneil@lanl.gov). Fax this information to the Procurement Assistant, Carol McNeil, at [cmcneil@lanl.gov](mailto:cmcneil@lanl.gov), Fax: 505-665-3300, Phone: 505-667-5866 to confirm receipt.
3. Questions to be addressed at the pre-bid conference will be received until Noon, local time, June 2, 2003. Communicate your questions in writing to the Contract Administrator, Dale Kemp, at [dalekemp@lanl.gov](mailto:dalekemp@lanl.gov) or by fax to 505-665-8842.
4. The written questions to be answered prior to receipt of proposals will be received until Noon, local time, June 17, 2003 and no later, for response by Amendment prior to the bid due date. Communicate your questions in writing to the Contract Administrator, Dale Kemp, at [dalekemp@lanl.gov](mailto:dalekemp@lanl.gov) or by fax to 505-665-8842. Questions will be answered by COB June 18, 2003.

END OF AMENDMENT: All other terms and conditions of the Solicitation remain unchanged. This amendment to the solicitation will be cited and made a contract document in any resulting contract.